

**Invitation for Bid (IFB)  
Terrazzo Maintenance Services  
S2023-28  
Addendum No. 2**

---

April 13, 2023

This Addendum No. 2 consists of **two (2)** pages. Bidders must acknowledge receipt of this Addendum No. 2 in Required Form A – Form of Transmittal Letter.

This Addendum No. 2 has the following information to be incorporated into the Invitation for Bid (IFB):

Item 1:                    **Attachment 1: Response to Bidder Questions**

Alex Buckles  
Purchasing & Supplier Diversity Manager

McCormick Place | ASM Terrazzo Maintenance Services  
 S2023-28  
 Addendum 2 – Attachment 1  
 Response to Bidder Questions

Bidders Question:		McCormick Place   ASM Global Response:
1	Please define the level of finish you are seeking for the grinding of the stairs and risers, ie; 100 grit, 200grit, etc.	50 grit up to 800 grit
2	Please define the finish you are seeking ( polish the floor surface)	Powder polish or sealer. Steps can't be slippery
3	Per the site visit, the staircase at the South Entrance, caulking was discussed as to pricing as an add on. Should complete removal and reinstallation of caulk be figured for the staircase in its entirety?	Caulk doesn't need to replace only clean it is good condition