

Invitation For Bid (IFB)
SOUTH MDF Uninterruptable Power Supplies Purchase
S2022-23
Addendum No. 1

June 23, 2022

This Addendum No. 1 consists of **one (1)** page. Bidders must acknowledge receipt of this Addendum No. 1 in Required Form A – Form of Transmittal Letter.

This Addendum No. 1 has the following information to be incorporated into the Request for Proposal (RFP):

Item 1: **Response to Proposer questions**

Alex Buckles
Purchasing & Supplier Diversity Manager

McCormick Place | ASM Global South MDF UPS
S2022-29
Addendum 1 – Attachment 1
Response to Bidder Questions

Bidders Question:		McCormick Place ASM Global Response:
1	Single phase or 3 phase? If single phase, is 120V output needed? Hardwired output, or outlets?	3 Phase 208V